

COLOREX EC/SD GROUNDING PROCEDURES

A minimum of one grounding strap must be installed for every 2,000 sq. ft. of uninterrupted tile.

Grounding points are typically located around the perimeter of the room or at grounded steel columns. At each grounding point, simply lay a minimum of 3' of the fabric ground strap into the wet adhesive and allow enough extra to extend up the wall to reach the grounding point.

After placing the grounding strap into the adhesive, spread additional adhesive on top of the strap and install the tile over it.

An "electrical end terminal" can easily be connected to the exposed end of the fabric grounding strap by twisting the end of the fabric strap, inserting the twisted fabric into the end of the terminal, and crimping the terminal to secure the fabric. The terminal can then be connected to the grounding point.

Commonly used end terminals include:

The Ring Terminal



or

The Spade Terminal



Note: It is the flooring contractor's responsibility to discuss the placement and connection of the grounding strap(s) prior to the installation of the flooring. The grounding strap(s) are normally connected to the grounding point by a licensed electrician.